# THE STANDARDS INSTITUTION OF ISRAEL



# Building Materials Laboratory

## Test Report No. 8411203381

in accordance with Clause 12 of the Standards Law, 1953

#### Details of order

The test was ordered by

: Bitum Petrochemical Industries Ltd.

Address

: 4 HaYetzira, Haifa Bay, 26111, ISRAEL

Date of order

: 28.3.04

## Description of sample

Polymer based sealant material, designated "Multigum" applied to the test samples by the customer representative.

### Sampling details

The sample was taken on 9.4.04 by a representative of the customer. Sample size: three specimens.

#### Nature of test

Compliance with the requirements of SI 4518 (November 2001) "Liquid applied, acrylic based flexible coating used in roof waterproofing" for a coating system, designated M in Clause 3.3.8.

This report contains 2 pages and may be used only in full.

The test results in this document refer only to the item tested.

#### Test conclusions

- The specimen was tested in accordance with the abovementioned clause and complies. It was not tested to the remaining clauses of the Standard.
- The test results are given on page 2.

This document is not approved for marking the product with the Standards Mark

Name

: Zohar Peisie

Section

Eng. Avi Burshtein

Position: Head, Sealing and Coating Materials

Position

Name

: Head, Durability of Buildings and Sealing Branch

18.04.04

# THE STANDARDS INSTITUTION OF ISRAEL



Building Materials Laboratory

Test Report No. 8411203381

Page 2 of 2 pages

# **Test results**

Clause no.	Property tested	Units		Test results	Requirements of SI 4518	Compliance with SI 4518
3.3.8	Dynamic bridging over a	1000 cycles of	1	No cracks appeared	No cracks shall	Complies
3.3.8.1	- before weathering - after conditioning in air Designation of coating system: M Coating material layer thickness: approximately 2.0 mm	1.0 mm	2	No cracks appeared	appear during or after the test	
			3	No cracks appeared		
		500 cycles of	1	No cracks appeared	No cracks shall	Complies
		3.0 mm	2	No cracks appeared	appear during or after the test	,
			3	No cracks appeared		

Invoice: no.: 2065745

Tel-Aviv: 18.04.04

F-WVRAHAM/Building/JJ#1BitumSesl doc